



10641 Highway 36
Covington, GA
30014

www.sunbeltbuilders.com

t 770.786.3031
f 770.786.3046

JACKSON COUNTY AIRPORT TERMINAL BUILDING

FireAway
636 Moore Street
Oxford, GA 30054
ph: 770-918-0527
Paul Green, Jr.
paul@atlantafiresprinklers.com

28-4820 Fire Alarm As-built



DEVICE MOUNTING HEIGHTS

FIRE ALARM PULL STATION - 48" Above Fin. Floor

FIRE ALARM STROBE ONLY - CEILING MOUNT

FIRE ALARM HORN STROBE - CEILING MOUNT

FIRE ALARM HORN STROBE - WALL MOUNT TO BE 92" AFF

WIRING NOTES

1. ALL WIRE RUNS SHALL BE CONTINUOUS WITH NO SPLICES BETWEEN DEVICES AND PANEL TERMINATIONS.
2. ALL DEVICES, PANELS ETC. SHALL BE INSTALLED PLUMB AND LEVEL. ALL CONDUITS SHALL BE PLUMB AND LEVEL.
3. REFER TO SPECIFICATIONS FOR INSTALLATION AND SCOPE REQUIREMENTS. NO DEVIATIONS TO THE SPECIFICATIONS ARE ALLOWED.
4. ALL CIRCUITS SHALL BE LABELED AND IDENTIFIED. CHECK CIRCUITS FOR SHORTS, GROUND/SHORTS. VERIFY ALL EOL (END OF LINE) RESISTORS ARE READ WITH A VOM FOR PROPER VALUES

FIRE ALARM SYSTEM

4300 Sq Ft

12'

10'

8'

6'

4'

2'

0'

$1\frac{1}{8}" = 1'-0"$

**The Design, Materials and installation of this system
Are in accordance with the requirements of NFPA 72, 2019 Edition**

AS-BUILT

636 Moore St., Oxford, Georgia 30054
770-918-0527 - Designer Email - paul@firetronicsllc.com

Paul Brian Green